



THUSO
DEVELOPMENT CONSULTANTS

PO Box 29312, Danhof 9310
75B General Dan Pienaar Drive
BLOEMFONTEIN
9301

Tel : 051 – 436 0357
Fax : 051 – 436 5938
E-mail: thuso@consulteng.co.za
Web: www.consulteng.co.za/thuso.html

'Promote Real Empowerment by Speeding up Service Delivery'

REG. NO. 2001/030172/07

19 November 2020

Our Ref: 1415_L2_KP

TO ALL TENDERERS

**CONTRACT: MIS 315 995A: PORT ST JOHNS REGIONAL WATER SUPPLY SCHEME
PHASE 6 CIVIL WORKS: NOTICE TO TENDERERS NO. 1**

The following is a Notice to Tenderers which form an integral part of the Tender Document and must be included in the Tender Document.

NTT 1.1 Section C of the Bill of Quantities: Operators Houses.

Item C22.2 specifically refers to SANS 1200 LD. Brick manholes. Contractors are required to price the brick manholes as per the details as set out in SANS 1200 LD page 13, for a manhole with a depth between 1.0 to 1.2m

NTT1.2 Additional Drawings

- 1368-0-1226: Maintenance house – Elevations
- 1368-0-1227: Maintenance house – Raft Foundation
- 1368-0-1229: Electrical supply
- 1368-0-1230: Septic Tank

The abovementioned drawings must be read in conjunction with items C22.3, C22.5 and C24.2 of the BOQ.

Item C27.1 for main electrical supply to Maintenance houses must make provision for the installation of the electrical supply from the Eskom connection to the houses that must include the electrical cable for a 60 AMP supply to the house and for a total length of 140m of trench excavations and backfill for each house. The cable must be a 16mm square copper 3 core cable.

NTT1.3 Section D: Refurbishment.

All item and materials as listed in this Section shall make provision for the supply and installation of all materials as listed in the BOQ.

Attached is Drawing 1368-0-106: Details of standpipe and connection, Item D29 must be read in conjunction of the listed drawing, the price for the isolating valve shall include supply and installation.

DIRECTORS:

P Mabandla (Managing)
L Laubscher (Pr Tech Eng; Pr CPM)



Membership No 843

Please acknowledge receipt of this Notice to Tenderers by signing the attached acknowledgement form and e-mail to OR Tambo District Municipality, e-mail to fingwa@gmail.com

Yours faithfully



J H PRETORIUS (Pr Tech Eng)
THUSO DEVELOPMENT CONSULTANTS

NOTICE TO TENDERERS NO. 1: CONTRACT MIS 315 995A

ACKNOWLEDGEMENT FORM

To : Mr. N Noto
From ; OR Tambo District Municipality
E-mail : fingwa@gmail.com

We hereby acknowledge receipt of Notice to Tenderers No. 1 and confirm that we as the undersigned contractor will incorporate this Notice in your Tender Document.

Signed on behalf of Contractor

Date

Print Name and Surname

Company Name